

## **Attestation of Conformity**

No. E8A 101050 0007 Rev. 00

**Holder of Certificate: KEHUA FRANCE SAS** 

3 Place Général de Gaulle

13001 Marseille **FRANCE** 

Name of Object: Converter

PV Grid-connected Inverter

KF-SPI3000-B2, KF-SPI3600-B2, KF-SPI4000-B2, Model(s):

KF-SPI4600-B2, KF-SPI5000-B2, KF-SPI6000-B2

**Description of** Input voltage:

Max. input power: **Object:** 

DC 100V~550V

4.05kW, 4.86kW, 5.4kW,

6.21kW, 6.75kW, 8.1kW AC 230V

Rated output voltage:

Rated frequency: 50Hz

Rated output power:

3kW, 3.6kW, 4kW,

4.6kW, 5kW, 6kW

Protection class:

**Tested** according to: EN 61000-6-2:2005

EN 61000-6-3:2007/A1:2011

This Attestation of Conformity is issued on a voluntary basis according to the Directive 2014/30/EU relating to electromagnetic compatibility. It confirms that the listed apparatus complies with all essential requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.:

4812818013700

Date,

2018-09-14

(Xiao Xu)

Page 1 of 1

After preparation of the necessary technical documentation as well as the EU Declaration of conformity the required CE marking can be affixed on the product. That Declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.